



FEB 19 2014

Lewis Nelson Tulare City Wastewater Plant 1875 S. West St. Tulare, CA 93274

Re: Notice of Minor Title V Permit Modification

District Facility # S-548 Project # S-1133793

Dear Mr. Nelson:

Enclosed is the District's analysis of your application for minor Title V permit modification for the facility identified above. You proposed a Title V minor permit modification to incorporate recently issued S-548-32-2 and '-32-3 into the Title V operating permit. The permits authorize modification of a 6.3 MMBtu/hr Hurst series 100 digester/natural gas-fired sludge heater by lowering the NOx emission factor and removing digester gas as a fuel source.

Enclosed is the engineering evaluation with the following attachments: proposed modified Title V permit, recently issued S-548-32-4 and '-32-5, emission increases, application, and previous Title V permit. This project will be subject to a 45-day EPA commenting period prior to the District taking final action.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,

Director of Permit Services

Enclosures

Gerardo C. Rios, EPA (w/enclosure) via email CC:

> Seved Sadredin Executive Director/Air Pollution Control Officer

TITLE V APPLICATION REVIEW

Minor Modification Project #'s: S-1133793

Engineer: Robert Rinaldi

Date: February 12, 2014

Facility Number: S-548

Facility Name:

Tulare City Wastewater Plant

Mailing Address: 1875 S. West St

Tulare, CA 93274

Reviewed by Asure ARE

FEB 1 3 2014

Contact Name: Lewis Nelson

Phone: (661) 654-7293

Responsible Official:

Dan Dorman

Title: City Manager

I. **PROPOSAL**

Tulare City Wastewater Plant is proposing a Title V minor permit modification to incorporate the recently issued ATC's S-548-32-4 and '-32-5 into the Title V operating permit.

The purpose of this evaluation is to identify all applicable requirements, determine if the facility will comply with the applicable requirements and to provide the legal and factual basis for the proposed revisions.

II. **FACILITY LOCATION**

The facility is located at 1875 S. West St., Tulare, CA.

III. EQUIPMENT DESCRIPTION

ATC S-548-32-2:

MODIFICATION OF 6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER: REDUCE NOX LIMIT TO 9 PPMV FOR RULE 4320 COMPLIANCE

ATC S-548-32-3:

MODIFICATION OF 6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER: REMOVE DIGESTER GAS AS A FUEL SOURCE

IV. SCOPE OF EPA AND PUBLIC REVIEW

This change to a Title V permit is considered to be a minor modification and, as such, requires no public review.

V. APPLICABLE REQUIREMENTS

District Rule 2520, <u>Federally Mandated Operating Permits</u> (Adopted June 21, 2001)

VI. DESCRIPTION OF PROPOSED MODIFICATIONS

The following condition will be modified in the S-548-32-2 Title V permit.

2. Emissions from the unit when fired on digester gas shall not exceed any of the following limits: 45 9 ppmvd NOx @ 3% O2 or 0.018 0.011 lb-NOx/MMBtu, 0.041 lb-SOx/MMBtu, 0.0005 lb-PM10/MMBtu, 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu, or 0.005 lb-VOC/MMBtu. [District Rules 2201, 4306 and 4320] Y

The equipment description will be modified in the S-548-32-3 Title V permit.

6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER

VII. COMPLIANCE

In accordance with Rule 2520, 3.20, these modifications:

- 1. Do not violate requirements of any applicable federally enforceable local or federal requirement:
- 2. Do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions:
- 3. Do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient impacts, or a visibility or increment analysis;
- 4. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include;
 - a. A federally enforceable emission cap assumed to avoid classification as a modification under any provisions of Title I of the Federal Clean Air Act; and
 - An alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Federal Clean Air Act; and
- Are not Title I modifications as defined in District Rule 2520 or modifications as defined in section 111 or 112 of the Federal Clean Air Act; and
- 6. Do not seek to consolidate overlapping applicable requirements.

In accordance with Rule 2520, the application meets the procedural requirements of section 11.4 by including;

- A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
- 2. The source's suggested draft permit; and
- 3. Certification by a responsible official that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used.

Tulare City Wastewater Plant Facility S-548 Project # S-1133793

VIII. ATTACHMENTS

- Proposed Title V Operating Permit A.
- Existing Title V Permit B.
- Authority to Construct Emissions Increases C.
- D.
- E. Application
- Compliance Certification Form F.

ATTACHMENT A

Proposed Modified Title V Operating Permit

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-548-32-5

EXPIRATION DATE: 1-1/30/2010

EQUIPMENT DESCRIPTION:

6.3 MMBTU/HR HURST SERIES 100 NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER

PERMIT UNIT REQUIREMENTS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
- 3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
- 4. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201 & 4320] Federally Enforceable Through Title V Permit
- 5. Emissions from the unit shall not exceed any of the following limits: 9 ppmvd NOx @ 3% O2 or 0.011 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.0005 lb-PM10/MMBtu, 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu, or 0.005 lb-VOC/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
- 6. Fuel used shall not exceed 151 MMBtu/day or 49,920 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
- 7. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 8. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: TULARE CITY WASTEWATER PLANT Location: 1875 S WEST ST, TULARE, CA 93274 S-548-32-5: Feb 13 2014 9:22AM - RINALDIR

- 9. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 10. Consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, 4320 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 11. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 12. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 13. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 14. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 17. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 18. This unit shall be tested for compliance with the NOx and CO emissions limits at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 19. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. NOx emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. CO emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 21. Stack gas oxygen shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 22. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070]

These terms and conditions and part of the Facility-wide Permit to Operate.

Facility Name: TULARE CITY WASTEWATER PLANT Location: 1875 S WEST ST, TULARE, CA 93274 8-548-32-5. Feb 13 2014 9:22AM -- RINALDIR

ATTACHMENT B

Existing Title V Permit

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-548-32-1

EXPIRATION DATE: 11/30/2016

EQUIPMENT DESCRIPTION:

6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER

PERMIT UNIT REQUIREMENTS

- 1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
- 2. Emissions from the unit when fired on digester gas shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, 0.041 lb-SOx/MMBtu, 0.0005 lb-PM10/MMBtu, 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu, or 0.005 lb-VOC/MMBtu. [District Rules 2201 and 4306] Federally Enforceable Through Title V Permit
- 3. Fuel used shall not exceed 151 MMBtu/day or 49,920 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
- 4. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
- 5. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
- 6. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
- 7. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: TULARE CITY WASTEWATER PLANT Location: 1875 S WEST ST, TULARE, CA 93274 S-548-32-1. Feb 12 2014 2:40PM - RINALDIR

- 8. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 9. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 10. This unit shall be tested for compliance with the NOx and CO emissions limits at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
- 11. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. NOx emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
- 12. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. CO emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
- 13. Stack gas oxygen shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4305 and 4306] Federally Enforceable Through Title V Permit
- 14. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070, 4305 and 4306] Federally Enforceable Through Title V Permit
- 15. On and after July 1, 2012, the permit unit shall be in full compliance with District Rule 4320 (adopted 10/16/08). [District Rule 4320] Federally Enforceable Through Title V Permit

ATTACHMENT C

Authorities to Construct





AUTHORITY TO CONSTRUCT

PERMIT NO: S-548-32-2 ISSUANCE DATE: 10/18/2011

LEGAL OWNER OR OPERATOR: TULARE CITY WASTEWATER PLANT

1875 S WEST ST

MAILING ADDRESS:

TULARE, CA 93274

LOCATION:

1875 S WEST ST TULARE. CA 93274

EQUIPMENT DESCRIPTION:

MODIFICATION OF 6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER: REDUCE NOX LIMIT TO 9 PPMV FOR RULE 4320 COMPLIANCE

CONDITIONS

- 1. The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
- 2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
- 4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
- 5. Emissions from the unit when fired on digester gas shall not exceed any of the following limits: 9 ppmvd NOx @ 3% O2 or 0.011 lb-NOx/MMBtu, 0.041 lb-SOx/MMBtu, 0.0005 lb-PM10/MMBtu, 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu, or 0.005 lb-VOC/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
- 6. Fuel used shall not exceed 151 MMBtu/day or 49,920 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seved Sadredin, Executive Director / APCO

- 7. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 8. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 9. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 10. Consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, 4320 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 11. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
- 12. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 13. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 14. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 17. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 18. This unit shall be tested for compliance with the NOx and CO emissions limits at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. [District Rule 4305] Federally Enforceable Through Title V Permit

- 19. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. NOx emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305] Federally Enforceable Through Title V Permit
- 20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. CO emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305] Federally Enforceable Through Title V Permit
- 21. Stack gas oxygen shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4305] Federally Enforceable Through Title V Permit
- 22. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit





AUTHORITY TO CONSTRUCT

ISSUANCE DATE: 12/29/2011 PERMIT NO: S-548-32-3

LEGAL OWNER OR OPERATOR: TULARE CITY WASTEWATER PLANT

MAILING ADDRESS:

1875 S WEST ST TULARE, CA 93274

LOCATION:

1875 S WEST ST

TULARE, CA 93274

EQUIPMENT DESCRIPTION:

MODIFICATION OF 6.3 MMBTU/HR HURST SERIES 100 DIGESTER/NATURAL GAS-FIRED SLUDGE HEATER WITH A POWER FLAME L NINVCR5-GG-30A BURNER: REMOVE DIGESTER GAS AS A FUEL SOURCE

CONDITIONS

- The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
- No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
- No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
- The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201 & 4320] Federally Enforceable Through Title V Permit
- Emissions from the unit when fired on digester gas shall not exceed any of the following limits: 9 ppmvd NOx @ 3% O2 or 0.011 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.0005 lb-PM10/MMBtu, 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu, or 0.005 lb-VOC/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
- Fuel used shall not exceed 151 MMBtu/day or 49,920 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU <u>MUST</u> NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

- 8. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 9. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 10. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 11. Consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules4305, 4306, 4320 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 12. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
- 13. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 14. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 18. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 19. This unit shall be tested for compliance with the NOx and CO emissions limits at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. [District Rule 4305] Federally Enforceable Through Title V Permit

- 20. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. NOx emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305] Federally Enforceable Through Title V Permit
- 21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. CO emissions during the source test shall be calculated as the arithmetic average of three 30-consecutive-minute test runs. [District Rule 4305] Federally Enforceable Through Title V Permit
- 22. Stack gas oxygen shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4305] Federally Enforceable Through Title V Permit
- 23. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

ATTACHMENT D

Emissions Increases

	SSIPE (lb/yr)				
	NOx	VOC	CO	SOx	PM10
ATC S-548-32-2	0	0	0	0	0
ATC S-548-32-3	0	0	0	0	0
TOTAL	0	0	0	0	0

ATTACHMENT E

Application

5-548-32-9 & - RECENTED SEP 27 2013

[] SIGNIFICANT MODIFICATION

San Joaquin Valley Air Pollution Control District Southern Region

Permit Application For:

☑ MINOR MODIFICATION

☑ ADMINISTRATIVE AMENDMENT

1. PERMIT TO BE ISSUED TO: CITY C	F TULARE				
2. MAILING ADDRESS:					
STREET/P.O. BOX: 1875 S. WEST ST					
CITY: TULARE	STATE: CA		9-DIGIT ZIP CODE: 93274		
CITY: BURNEY	STATE: CTT		Zir GODB. 552.		
3. LOCATION WHERE THE EQUIPMENT WIL	INSTALLATION DATE:				
STREET: 1875 S. WEST ST.	CITY:	7-1-2012			
SW16 4 SECTION 20S TOWNSHIE	24E RANGE				
4. GENERAL NATURE OF BUSINESS: WAS	TEWATER TRE	EATMENT			
5. DESCRIPTION OF EQUIPMENT OR MODIF (include Permit #'s if known, and use additional S-548-32-2, 32-3 Dual fuel boile	al sheets if necessary)				
6. TYPE OR PRINT NAME OF APPLICANT: LEWIS R. NELSON			TITLE OF APPLICANT: PUBLIC WORKS DIRECTOR		
7. SIGNATURE OF APPLICANT: DATE: 9/27/13			PHONE: (559)684-4318 FAX: (559)685-2378 EMAIL: lnelson@ci.tulare.ca.us		
For APCD Use Only:		N	10 money.		
DATE STAMP	FILING FEE RECEIVED : \$ DATE PAID: PROJECT NO:	51133793	CHBCK#: FACILITY ID: 5-548		

ATTACHMENT F

Compliance Certification Form



San Joaquin Valley Unified Air Pollution Control District



TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

TYPE OF PERMIT ACTION (Check appropriate box)

[] SIGNIFICANT PERMIT MODIFICATION [] ADMINISTRATIVE MINOR PERMIT MODIFICATION AMENDMENT
COMPANY NAME: City of Tulare FACILITY ID: -
1. Type of Organization: [] Corporation [] Sole Ownership [] Government [] Partnership [] Utility
2. Owner's Name: City of Tulock
3. Agent to the Owner: Dun Dormon, City Manager
I. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):
Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.
I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:
8, D- Down 2/6/2014
Signature of Responsible Official Date
Dan Dorwon
Name of Responsible Official (please print)
City Manager
Title of Responsible Official (please print)